

La Sociedad:

CMO
5 RUE CHABANAIS
FR-75002 PARIS

Está autorizada para colocar la etiqueta "Clasificación de Reacción al Fuego de Productos de Construcción" según el Nº de informe 2017AN2922.



aitex
textile research institute

**CLASIFICACIÓN DE REACCIÓN AL FUEGO DE:
PRODUCTOS DE CONSTRUCCIÓN**

Nº 17AN2922

La muestra referenciada como:

"CMO WLI 01"

ha sido objeto de ensayo de acuerdo con las normas UNE-EN ISO 11925-2:2011 (equivalente a EN ISO 11925-2:2010) y UNE-EN 13823:2012+A1:2016 (equivalente a EN 13823:2010+A1:2014), quedando clasificada según norma UNE-EN 13501-1:2007+A1:2010 (equivalente a EN 13501-1:2007+A1:2009) como:

"C-s1,d0"

Alcoy, 30 de Noviembre de 2017.



Celia Dolça

RESPONSABLE LAB. COMPORTAMIENTO AL FUEGO



Reaction to fire



The applicant:

CMO
5 RUE CHABANAIS
FR-75002 PARIS

is authorized to place the label "Classification of Reaction to Fire of Construction Products." according to the report Nº 2017AN2922



aitex
textile research institute

CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº 17AN2922

The sample reference:

" CMO WLI 01 "

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2012+A1:2016 (equivalent to EN 13823:2010+A1:2014). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

"C-s1,d0"

Alcoy, November 30th 2017.



Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.