



The applicant: **CMO PARIS**
35 RUE DE BELLECHASSE
FR-75007 PARIS

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2020AN1742



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 20AN1742

The sample reference:

“ BOIS WBO 01 ”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“B-s1,d0”

Alcoy, November 18th 2020.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.