



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

CMO PARIS

35 RUE DE BELLECHASSE
FR-75007 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2022AN6769.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 22AN6769

The sample referenced as:

"CMO WME 01"

has been tested according to the standards
. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

3rd of October 2022



aitex

Date: 03/10/2022 11:43:07

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.