



The applicant:

CMO
5 RUE CHABANAIS
FR-75002 PARIS

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN2956



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 18AN2956

The sample reference:

“OPALE MURAL”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s1,d0”

Alcoy, October 30th 2018.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.